



## PERFORMANCE TEST REPORT

Air Permeability, Watertightness an Resistance to Wind Load

Test Report No: 010.016.1 / 2010




Rendered to	: Burak Aluminium San. ve Tic. A.Ş.	Norms Applied	: EN 12153
			: EN 12155
			: EN 12179
Product	: Curtain Walling ALS50		:
		Classification Norms	: EN 12152
			: EN 12154
			: EN 13116
Sample Size	: 2400 mm x 7700 mm		:
Sample Description	: Top Hang Window (2 pieces)		:
	: 6 / 16 / 6 Double Glass		:
	:	Test Comp. Date	: 22.12.2010
Test Performed	: Air Permeability - Static	Report Date	: 25.12.2010
	: Watertightness - Static	Record Retention Date	: 25.12.2013
	: Wind Load - Static	Number of Pages	: 10
		Number of Annex Pages	: 10

**Test Results** : The Test sample performed in accordance of to following classifications

Air Penetration	: EN 12152 - Class A4 (600 Pa)
Water Tightness	: EN 12154 - Class R7 (600 Pa) *** (see to section 6 in the report)
Wind Resistance	: EN 13116 - OK (1100 Pa)

\* Calibration of the test equipments certified by CEBTP / France referenced to report BEB1-9-2024-1/2

\*\*This Test Report includes spesific test data, results, photographic documention and build drawings of the sample submitted for testing only and thus does not prejudice other related products.

  
Murat Seyhan  
General Manager

  
Oktay Usta  
Testing Manager



## CONTENTS

1. PREFACE.....	2
2. TEST PARTICIPANTS .....	2
3. DESCRIPTION OF TEST SAMPLE .....	3
4. TEST RESULTS.....	4
4.1 Test Conditions .....	4
4.2 Pressure Sequence .....	4
4.3 Air Permeability .....	4
4.4 Watertightness Under Static Pressure.....	7
4.5 Resistance to Wind Load .....	7
4.6 Increased Load Test( Safety Test - Secure Load ) ( <i>Could not be measured</i> ).....	10
5. REVISIONS MADE ACCORDING TO TEST RESULTS .....	10
6. RESULT .....	10
6.1. Results and classification.....	10
7. ANNEXES	
7.1. Sample Drawings and Details	
7.2. Certification of the Calibration	
7.3. Photos taken during the test.	

